

Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **City Kids LLC**

City: **Rapid City**

Provider Number: **016598108**

Inspector: **Ann Marie Sailer**

Date of Inspection: **03/27/2018**

Time of Inspection: **2:00 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

2. Does the main level have at least two remote exits that discharge directly to the outside? 61:15:06:05
NOTE: These main exits cannot pass through a kitchen.

| | | | | | |
|---|--|----------------------------|-------------------------|-------------------|-------------------|
| <p>Corrections To Be Made:</p> <p>Exit doors need to have 'one action' knobs; to be able to unlock/open in one motion.</p> | <p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">04/10/2018</td> <td style="text-align: center;">04/25/2018</td> </tr> </table> <p>Status: Corrected</p> | Suggested Completion Date: | Actual Completion Date: | 04/10/2018 | 04/25/2018 |
| Suggested Completion Date: | Actual Completion Date: | | | | |
| 04/10/2018 | 04/25/2018 | | | | |

Jess Jansson

Provider Signature

03/27/2018

Date

Ann Marie Sailer

Inspector Signature

03/27/2018

Date