

# Facility Safety Inspection

## Fire & Life Safety / Environmental Health

### Before & After School Center - School Location

### Compliance Plan

Provider's Name: **Kidstop - Edgemont**

City: **Edgemont**

Provider Number: **016598184**

Inspector: **Jennifer  
Preuninger**

Date of Inspection: **04/04/2018**

Time of Inspection: **4:46 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## B. ENVIRONMENTAL HEALTH

17. Is the heating and cooling system maintained and inspected annually? 67:42:11:12

Corrections To Be Made:

**Heating and cooling unit needs to be inspected annual. Program needs to provide verification of the inspection.**

Agency Action:

### Compliance Plan

Suggested  
Completion  
Date:

**04/14/2018**

Actual  
Completion  
Date:

**04/13/2018**

Status: **Corrected**

**Amanda Allen**

Provider Signature

**04/04/2018**

Date

**Jennifer Preuninger**

Inspector Signature

**04/04/2018**

Date