

Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Kyle Learning Center**

City: **Kyle**

Provider Number: **016599289**

Inspector: **Tina Uecker**

Date of Inspection: **03/07/2018**

Time of Inspection: **12:32 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

B. ENVIRONMENTAL HEALTH

40. To prevent entrance of insects, are all outside openings protected by tight-fitting, self-closing doors, a closed window, screening, controlled air currents, or other means? Are they maintained in good repair?
67:42:11:36

<p>Corrections To Be Made:</p> <p>The exit door near the kitchen has tape on it to prevent the draft from coming in. It is not tight fitting. It needs to be fixed to prevent drafts and insects from coming in.</p> <p>The exit door has dead bolts on them. These need to be removed.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">03/21/2018</td> <td style="text-align: center;">03/13/2018</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	03/21/2018	03/13/2018
Suggested Completion Date:	Actual Completion Date:				
03/21/2018	03/13/2018				

Tara High Horse

06/04/2018

Tina Uecker

06/04/2018

Provider Signature

Date

Inspector Signature

Date