

Facility Safety Inspection

Fire & Life Safety / Environmental Health

Licensed Day Care Programs

Compliance Plan

Provider's Name: **Zion Lutheran Preschool and Daycare**

City: **Rapid City**

Provider Number: **016599518**

Inspector: **Jon Farrar**

Date of Inspection: **06/25/2019**

Time of Inspection: **9:50 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

14. In storage rooms, are combustible materials maintained at least 2 feet below the ceiling or 18 Inches below sprinkler head deflectors? 67:42:10:18

Corrections To Be Made:

Combustible items are stored within 18" of the ceiling in the library. Remove items that are stored within this space. Correction: Program removed the items.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

07/01/2019

Actual
Completion
Date:

07/11/2019

Status: **Corrected**

Hope Genzlinger

Provider Signature

06/25/2019

Date

Jon Farrar

Inspector Signature

06/25/2019

Date