

Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **SWST Head Start West**

City: **Agency Village**

Provider Number: **017508141**

Inspector: **Eric Janke**

Date of Inspection: **09/11/2018**

Time of Inspection: **9:53 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

14. In storage rooms, are combustible materials maintained at least 2 feet below the ceiling or 18 Inches below sprinkler head deflectors? 67:42:10:18

Corrections To Be Made:

Stuffed animals and cardboard boxes in storage room need to be 18" below sprinkler heads. Provider can remove the items to meet compliance. Provider moved the items 18" lower than the sprinkler heads.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

09/12/2018

Actual
Completion
Date:

10/03/2018

Status: **Corrected**

Lynn Halbert

Provider Signature

09/11/2018

Date

Eric Janke

Inspector Signature

09/11/2018

Date