

Facility Safety Inspection

Fire & Life Safety / Environmental Health

Licensed Day Care Programs

Compliance Plan

Provider's Name: **Peace C.A.R.E.**

City: **Sioux Falls**

Provider Number: **018037458**

Inspector: **Dwight Johnson**

Date of Inspection: **01/14/2020**

Time of Inspection: **11:00 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

10. If providing care for children under 5 years of age, are there self-closing, or tamper resistant childproof electrical covers on all outlets? 67:42:11:10

Corrections To Be Made:

The library outlets do not have the proper protective measures over or inside of the outlets.

***Self-closing outlets installed.**

Agency Action:

Compliance Plan

Suggested
Completion
Date:

01/21/2020

Actual
Completion
Date:

01/24/2020

Status: **Corrected**

14. In storage rooms, are combustible materials maintained at least 2 feet below the ceiling or 18 Inches below sprinkler head deflectors? 67:42:10:18

Corrections To Be Made:

The Froggie room has decorations 10-12 inches from the ceiling installed with sprinklers and are not using nylon string for suspension.

***Decorations removed.**

Agency Action:

Compliance Plan

Suggested
Completion
Date:

01/21/2020

Actual
Completion
Date:

01/14/2020

Status: **Corrected**

B. ENVIRONMENTAL HEALTH

23. If carpeting is used, is it maintained in good repair? 67:42:11:38

Corrections To Be Made:

Several rooms have the carpet seams opening and fraying.

***All loose carpet strings have been trimmed.**

Agency Action:

Compliance Plan

Suggested
Completion
Date:

02/14/2020

Actual
Completion
Date:

01/14/2020

Status: **Corrected**

C. FOOD SERVICE

76. Is food free from spoilage or contamination and safe for human consumption? 67:42:11:16

Corrections To Be Made:

The refrigerator in the infant's room is measuring an inspected temperature of 41.9 degrees F. The director turned the temperature control knob down during inspection.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

02/14/2020

Actual
Completion
Date:

01/14/2020

Status: **Corrected**

95. Are all utensils/equipment stored at least six inches above the floor in a clean, dry, protected location, and not placed under exposed sewer or water lines except for fire protection sprinkler lines?
67:42:11:29

Corrections To Be Made:

Cartons of single-use paper plates used by the daycare are found stored on the floor in the dry storage room in the kitchen.

***Paper plates have been moved.**

Agency Action:

Compliance Plan

Suggested
Completion
Date:

01/21/2020

Actual
Completion
Date:

01/14/2020

Status: **Corrected**

Tara Foley

Provider Signature

01/14/2020

Date

Dwight Johnson

Inspector Signature

01/14/2020

Date