

# Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Little Pheasants**

City: **Parker**

Provider Number: **018040300**

Inspector: **Clint Rux**

Date of Inspection: **08/08/2018**

Time of Inspection: **2:15 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## A. FIRE AND LIFE SAFETY

9. In storage rooms, are combustible materials maintained at least 2 feet below the ceiling or 18 Inches below sprinkler head deflectors? 67:42:10:18

<p>Corrections To Be Made:</p> <p><b>Combustible material was stored within 2 feet of the ceiling in the furnace/laundry room. These materials must not be stored within 2 feet of the ceiling.</b></p> <p><b>*Combustible materials were removed and are now stored more than 2 feet below the ceiling.</b></p>	<p>Agency Action:</p> <p><b>Compliance Plan</b></p> <table style="width: 100%;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;"><b>08/15/2018</b></td> <td style="text-align: center;"><b>08/29/2018</b></td> </tr> </table> <p>Status: <b>Corrected</b></p>	Suggested Completion Date:	Actual Completion Date:	<b>08/15/2018</b>	<b>08/29/2018</b>
Suggested Completion Date:	Actual Completion Date:				
<b>08/15/2018</b>	<b>08/29/2018</b>				

**Dawn Muller**

**08/08/2018**

**Clint Rux**

**08/08/2018**

Provider Signature

Date

Inspector Signature

Date