

Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Little Pheasants**

City: **Parker**

Provider Number: **018040300**

Inspector: **Kelly Gnat**

Date of Inspection: **10/01/2019**

Time of Inspection: **11:31 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

14. In storage rooms, are combustible materials maintained at least 2 feet below the ceiling or 18 Inches below sprinkler head deflectors? 67:42:10:18

<p>Corrections To Be Made:</p> <p>Please remove the paint and polyurethane that is stored on the top shelf in the laundry room. These items are considered combustible.</p> <p>*Combustible items have been removed.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">10/30/2019</td> <td style="text-align: center;">10/03/2019</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	10/30/2019	10/03/2019
Suggested Completion Date:	Actual Completion Date:				
10/30/2019	10/03/2019				

Regina McKenney

10/01/2019

Provider Signature

Date

Kelly Gnat

10/01/2019

Inspector Signature

Date