

# Family Day Care Inspection Compliance Plan

Provider's Name: **Jodi Walker-Swenson**

City: **Sioux Falls**

Provider Number: **018041873**

Inspector: **Elijah Ehresmann**

Date of Inspection: **10/10/2019**

Time of Inspection: **2:05 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## B. Record Keeping/Fire Safety & Emergency Weather Drills

30. Does each child's record contain all required information? 67:42:16:13

Corrections To Be Made:

**EVV - Immunization Records  
KY - Immunization Records**

Agency Action:

### Compliance Plan

Suggested  
Completion  
Date:

**11/10/2019**

Actual  
Completion  
Date:

**11/07/2019**

Status: **Corrected**

## C. Health & Safety Features of the Home - Indoor Environmental Observations

69. Is the hot water temperature at hand washing sinks maintained at 120 degrees or lower?  
67:42:03:11.05

Corrections To Be Made:

**The hot water temperature of the handsink in the children's bathroom  
measured at 125 degrees during the inspection.**

**The hot water temperature at the handwashing sinks must be maintained  
at 120 degrees or lower.**

**Correction: The hot water temperature at the handwashing sink measured  
at 100 degrees.**

Agency Action:

### Compliance Plan

Suggested  
Completion  
Date:

**11/10/2019**

Actual  
Completion  
Date:

**11/07/2019**

Status: **Corrected**

**Jodi Walker Swenson**  
\_\_\_\_\_  
Provider Signature

**10/10/2019**  
\_\_\_\_\_  
Date

**Elijah Ehresmann**  
\_\_\_\_\_  
Inspector Signature

**10/10/2019**  
\_\_\_\_\_  
Date