

Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Hope C.A.R.E. Day Care #1**

City: **Sioux Falls**

Provider Number: **018041885**

Inspector: **Elijah Ehresmann**

Date of Inspection: **07/08/2019**

Time of Inspection: **11:48 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

B. ENVIRONMENTAL HEALTH

50. Is the heating and cooling system maintained and inspected annually? 67:42:11:12

<p>Corrections To Be Made:</p> <p>The heating and cooling system documentation was not available at the time of the inspection.</p> <p>The heating and cooling system must be inspected annually.</p> <p>Correction: The heating and cooling system was inspected on 8-30-2019.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 60%;">Suggested Completion Date:</td> <td style="width: 40%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">08/08/2019</td> <td style="text-align: center;">08/30/2019</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	08/08/2019	08/30/2019
Suggested Completion Date:	Actual Completion Date:				
08/08/2019	08/30/2019				

Katie Duncan

Provider Signature

07/08/2019

Date

Elijah Ehresmann

Inspector Signature

07/08/2019

Date