

Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Go Kids Daycare & Learning Center**

City: **Sioux Falls**

Provider Number: **018042120**

Inspector: **Ron Werner**

Date of Inspection: **06/27/2018**

Time of Inspection: **9:33 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

12. Are exits and exit corridors maintained in a safe manner? 61:15:05:05 NOTE: Exits can't pass through storeroom, bathroom, kitchen; corridor & aisle widths of 36 inches; exits cannot be obstructed.

<p>Corrections To Be Made:</p> <p>Emergency light not working on 1st floor by elevator.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">07/27/2018</td> <td style="text-align: center;">07/06/2018</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	07/27/2018	07/06/2018
Suggested Completion Date:	Actual Completion Date:				
07/27/2018	07/06/2018				

B. ENVIRONMENTAL HEALTH

50. Is the heating and cooling system maintained and inspected annually? 67:42:11:12

Corrections To Be Made:	Agency Action:	
	Compliance Plan	
	Suggested Completion Date:	Actual Completion Date:
	07/27/2018	07/06/2018
	Status: Corrected	

C. FOOD SERVICE

97. If a home-style dishwasher is used, does it have a hot water sanitizing cycle with water reaching 150 degrees F and the sanitizing cycle runs to completion without interruption? 67:42:11:07

Corrections To Be Made:	Agency Action:	
	Compliance Plan	
	Suggested Completion Date:	Actual Completion Date:
	06/27/2018	07/06/2018
	Status: Corrected	

Dishwasher closest to the service area was not set on sanitizer cycle

Terri Monshaugen

 Provider Signature

06/27/2018

 Date

Ron Werner

 Inspector Signature

06/27/2018

 Date