

# Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Go Kids Daycare & Learning Center**

City: **Sioux Falls**

Provider Number: **018042120**

Inspector: **Dwight Johnson**

Date of Inspection: **06/26/2019**

Time of Inspection: **2:00 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## A. FIRE AND LIFE SAFETY

14. In storage rooms, are combustible materials maintained at least 2 feet below the ceiling or 18 Inches below sprinkler head deflectors? 67:42:10:18

<p>Corrections To Be Made:</p> <p><b>Decorations in the Toddler Room are hung too close to the ceiling. The decorations need to be at least two feet from the ceiling and hung with fishing line.</b></p> <p><b>***The decorations have been removed from the ceiling.</b></p>	<p>Agency Action:</p> <p><b>Compliance Plan</b></p> <table border="0"> <tr> <td style="padding-right: 20px;">Suggested Completion Date:</td> <td>Actual Completion Date:</td> </tr> <tr> <td style="padding-right: 20px;"><b>07/10/2019</b></td> <td><b>07/22/2019</b></td> </tr> </table> <p>Status: <b>Corrected</b></p>	Suggested Completion Date:	Actual Completion Date:	<b>07/10/2019</b>	<b>07/22/2019</b>
Suggested Completion Date:	Actual Completion Date:				
<b>07/10/2019</b>	<b>07/22/2019</b>				

## B. ENVIRONMENTAL HEALTH

58. Are cleaning supplies kept inaccessible to children? 67:42:11:40

Corrections To Be Made:

**The janitor's closet is easily accessible to children passing by in the hallway. The door was unlocked and several potentially hazardous chemicals and items were within reach.**

**\*\*\*The door was immediately locked during the inspection making the supplies inaccessible to children.**

Agency Action:

**Compliance Plan**

Suggested  
Completion  
Date:

Actual  
Completion  
Date:

**06/26/2019**

**06/26/2019**

Status: **Corrected Immediately**

**Terri**

Provider Signature

**06/26/2019**

Date

**Dwight Johnson**

Inspector Signature

**06/26/2019**

Date