

Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Honey Bee Academy**

City: **Brandon**

Provider Number: **018042215**

Inspector: **Elijah Ehresmann**

Date of Inspection: **06/18/2019**

Time of Inspection: **2:59 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

10. If providing care for children under 5 years of age, are there self-closing, or tamper resistant childproof electrical covers on all outlets? 67:42:11:10

Corrections To Be Made:

There is an electrical outlet that does not have a tamper resistant cover in the 4-year old room.

***New cover on outlet observed on 06/27/19.**

Agency Action:

Compliance Plan

Suggested
Completion
Date:

06/25/2019

Actual
Completion
Date:

06/27/2019

Status: **Corrected**

B. ENVIRONMENTAL HEALTH

37. Are toilet rooms and fixtures clean and in good repair? 67:42:11:06

Corrections To Be Made:	Agency Action:	
There is paint missing on the back wall of the boy's bathroom. Walls are to be smooth and easily cleanable. *Wall repair observed on 06/27/19	Compliance Plan	
	Suggested Completion Date:	Actual Completion Date:
	07/18/2019	06/27/2019
	Status: Corrected	

58. Are cleaning supplies kept inaccessible to children? 67:42:11:40

Corrections To Be Made:	Agency Action:	
Bleach water and antibacterial creams were accessible to the children in 2-year old room. These items must be inaccessible to children in care. *Items moved as of 06/27/19.	Compliance Plan	
	Suggested Completion Date:	Actual Completion Date:
	06/18/2019	06/27/2019
	Status: Corrected	

Nicole Morey

Provider Signature

06/18/2019

Date

Elijah Ehresmann

Inspector Signature

06/18/2019

Date