

Facility Safety Inspection

Fire & Life Safety / Environmental Health

Licensed Day Care Programs

Compliance Plan

Provider's Name: **Kidz Academy**

City: **Sioux Falls**

Provider Number: **018042386**

Inspector: **Brenda Sharkey**

Date of Inspection: **06/26/2018**

Time of Inspection: **11:13 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

11. Are exit signs provided over each exit, and where necessary to identify a change in the direction of egress travel? 61:15:05:05 NOTE: Exit signs must be interior or exterior illuminated or self-luminous.

Corrections To Be Made:

Exit light batteries are dead throughout the daycare.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

07/26/2018

Actual
Completion
Date:

08/15/2018

Status: **Corrected**

B. ENVIRONMENTAL HEALTH

50. Is the heating and cooling system maintained and inspected annually? 67:42:11:12

Corrections To Be Made:

No documentation available for annual inspection

Agency Action:

Compliance Plan

Suggested
Completion
Date:

07/26/2018

Actual
Completion
Date:

07/11/2018

Status: **Corrected**

56. Are toys, capable of being placed in a child's mouth, washed, rinsed and sanitized daily using a solution of one ounce household bleach to two gallons water or in a mechanical dishwasher?
67:42:11:07

Corrections To Be Made:

Toys not being sanitized with bleach and water mixture in all rooms

Agency Action:

Compliance Plan

Suggested
Completion
Date:

07/26/2018

Actual
Completion
Date:

07/11/2018

Status: **Corrected**

Randi Melton

Provider Signature

06/26/2018

Date

Brenda Sharkey

Inspector Signature

06/26/2018

Date