

Facility Safety Inspection

Fire & Life Safety / Environmental Health

Licensed Day Care Programs

Compliance Plan

Provider's Name: **Kidz Academy**

City: **Sioux Falls**

Provider Number: **018042386**

Inspector: **Dwight Johnson**

Date of Inspection: **06/24/2019**

Time of Inspection: **12:00 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

11. Are exit signs provided over each exit, and where necessary to identify a change in the direction of egress travel? 61:15:05:05 NOTE: Exit signs must be interior or exterior illuminated or self-luminous.

Corrections To Be Made:

The exit sign in the infant's room is not illuminated nor does the backup setting work correctly.

***Exit sign has been repaired.**

Agency Action:

Compliance Plan

Suggested
Completion
Date:

07/24/2019

Actual
Completion
Date:

07/10/2019

Status: **Corrected**

C. FOOD SERVICE

93. Is kitchenware and food contact surfaces of equipment washed, rinsed and sanitized after each use and following any interruption of operations? 67:42:11:07

Corrections To Be Made:

The mounted in-place can opener in the kitchen needs to be cleaned and sanitized. The blade, blade cavity and mount on the table are contaminated with built-up food residue and meat shavings from use.

***Can opener cleaned at the time of the inspection.**

Agency Action:

Compliance Plan

Suggested
Completion
Date:

06/24/2019

Actual
Completion
Date:

06/24/2019

Status: **Corrected Immediately**

Olivia Agyeman

Provider Signature

06/24/2019

Date

Dwight Johnson

Inspector Signature

06/24/2019

Date