

Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Truks N Trykes 2**

City: **Sioux Falls**

Provider Number: **018042489**

Inspector: **Dwight Johnson**

Date of Inspection: **06/25/2019**

Time of Inspection: **10:00 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

14. In storage rooms, are combustible materials maintained at least 2 feet below the ceiling or 18 Inches below sprinkler head deflectors? 67:42:10:18

<p>Corrections To Be Made:</p> <p>Items in the gym are suspended too close to the ceiling. The items need to be at least two feet from the ceiling and on a nylon string.</p> <p>***The hanging items have been removed from the ceiling.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">06/25/2019</td> <td style="text-align: center;">07/01/2019</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	06/25/2019	07/01/2019
Suggested Completion Date:	Actual Completion Date:				
06/25/2019	07/01/2019				

B. ENVIRONMENTAL HEALTH

58. Are cleaning supplies kept inaccessible to children? 67:42:11:40

Corrections To Be Made:

Several rooms containing bleach and cleaning supplies were open and accessible to the children. The items need to be inaccessible to children.

*****The cleaning supplies have been moved and are inaccessible to children.**

Agency Action:

Compliance Plan

Suggested
Completion
Date:

06/25/2019

Actual
Completion
Date:

07/01/2019

Status: **Corrected**

Misti Totten

Provider Signature

06/25/2019

Date

Dwight Johnson

Inspector Signature

06/25/2019

Date