

Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Truks-N-Trykes 2**

City: **Sioux Falls**

Provider Number: **018042489**

Inspector: **Carrie Lewis**

Date of Inspection: **10/01/2020**

Time of Inspection: **1:03 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

B. ENVIRONMENTAL HEALTH

50. Is the heating and cooling system maintained and inspected annually? 67:42:11:12

<p>Corrections To Be Made:</p> <p>There is not verification of the annual heating and cooling system inspection. The heating and cooling system needs to be inspected annually.</p> <p>***The documentation for the annual heating and cooling system inspection was received by the Office of Licensing & Accreditation.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">10/15/2020</td> <td style="text-align: center;">10/20/2020</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	10/15/2020	10/20/2020
Suggested Completion Date:	Actual Completion Date:				
10/15/2020	10/20/2020				

Kimberly Darnall

10/01/2020

Provider Signature

Date

Carrie Lewis

10/01/2020

Inspector Signature

Date