

Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Snicklefritz Prep**

City: **Sioux Falls**

Provider Number: **018042561**

Inspector: **Russ Lauritsen**

Date of Inspection: **06/26/2018**

Time of Inspection: **8:47 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

B. ENVIRONMENTAL HEALTH

41. Is each bathroom provided with natural or mechanical ventilation? 67:42:11:06

Corrections To Be Made:

**Mechanical ventilation in both bathrooms do not seem to be working.
Repair to working order.**

Agency Action:

Compliance Plan

Suggested
Completion
Date:

07/27/2018

Actual
Completion
Date:

07/19/2018

Status: **Corrected**

Amber Vandenberg

Provider Signature

06/26/2018

Date

Russ Lauritsen

Inspector Signature

06/26/2018

Date