

# Facility Safety Inspection

## Fire & Life Safety / Environmental Health

### Licensed Day Care Programs

### Compliance Plan

Provider's Name: **Precious Angels Learning Center**

City: **Sioux Falls**

Provider Number: **018042647**

Inspector: **Dwight Johnson**

Date of Inspection: **07/08/2020**

Time of Inspection: **3:00 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## A. FIRE AND LIFE SAFETY

12. Are exits and exit corridors maintained in a safe manner? 61:15:05:05 NOTE: Exits can't pass through storeroom, bathroom, kitchen; corridor & aisle widths of 36 inches; exits cannot be obstructed.

### Corrections To Be Made:

**During the inspection, the exit door in the rear classroom was blocked.**

**All exits must be maintained at a minimum of 36 inches width.**

**Correction: The director moved the items to ensure the exits are maintained in a safe manner.**

**Two emergency lighting units (North side of the kitchen and Monkey room) were not operational at the time of the inspection.**

**Emergency lighting must be operational.**

**Correction: The emergency lighting units were fixed to ensure they are operational.**

### Agency Action:

### Compliance Plan

Suggested  
Completion  
Date:

**07/08/2020**

Actual  
Completion  
Date:

**07/27/2020**

Status: **Corrected**

## B. ENVIRONMENTAL HEALTH

50. Is the heating and cooling system maintained and inspected annually? 67:42:11:12

Corrections To Be Made:

**Documentation for the annual heating and cooling system inspection was not available at the time of the inspection.**

**The heating and cooling system must be maintained and inspected annually.**

**Correction: Documentation for the annual heating and cooling system inspection was provided to CCS.**

Agency Action:

**Compliance Plan**

Suggested  
Completion  
Date:

Actual  
Completion  
Date:

**08/08/2020**

**07/27/2020**

Status: **Corrected**

**Cayla Rush**

Provider Signature

**07/08/2020**

Date

**Dwight Johnson**

Inspector Signature

**07/08/2020**

Date