

Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **First Adventure Learning Center LLC**

City: **Sioux Falls**

Provider Number: **018042656**

Inspector: **Charles Anderson**

Date of Inspection: **05/15/2018**

Time of Inspection: **10:45 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

14. In storage rooms, are combustible materials maintained at least 2 feet below the ceiling or 18 Inches below sprinkler head deflectors? 67:42:10:18

<p>Corrections To Be Made:</p> <p>The sprinkler head is obstructed in the art supply room.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">05/15/2018</td> <td style="text-align: center;">05/15/2018</td> </tr> </table> <p>Status: Corrected Immediately</p>	Suggested Completion Date:	Actual Completion Date:	05/15/2018	05/15/2018
Suggested Completion Date:	Actual Completion Date:				
05/15/2018	05/15/2018				

B. ENVIRONMENTAL HEALTH

56. Are toys, capable of being placed in a child's mouth, washed, rinsed and sanitized daily using a solution of one ounce household bleach to two gallons water or in a mechanical dishwasher? 67:42:11:07

<p>Corrections To Be Made:</p> <p>Bleach water tested too strong. Inspector recommended a standard measuring device be used.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table border="0"> <tr> <td>Suggested Completion Date:</td> <td>Actual Completion Date:</td> </tr> <tr> <td>05/29/2018</td> <td>05/15/2018</td> </tr> <tr> <td colspan="2">Status: Corrected</td> </tr> </table>	Suggested Completion Date:	Actual Completion Date:	05/29/2018	05/15/2018	Status: Corrected	
Suggested Completion Date:	Actual Completion Date:						
05/29/2018	05/15/2018						
Status: Corrected							

57. Are dining tables sanitized before & after each meal with a solution of one ounce household bleach to two gallons of water? 67:42:11:07

<p>Corrections To Be Made:</p> <p>Bleach water tested too strong. Inspector recommended a standard measuring device be used.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table border="0"> <tr> <td>Suggested Completion Date:</td> <td>Actual Completion Date:</td> </tr> <tr> <td>05/29/2018</td> <td>05/15/2018</td> </tr> <tr> <td colspan="2">Status: Corrected</td> </tr> </table>	Suggested Completion Date:	Actual Completion Date:	05/29/2018	05/15/2018	Status: Corrected	
Suggested Completion Date:	Actual Completion Date:						
05/29/2018	05/15/2018						
Status: Corrected							

Kelli Jurgensen

 Provider Signature

05/15/2018

 Date

Charles Anderson

 Inspector Signature

05/15/2018

 Date