

Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **First Adventure Learning Center LLC**

City: **Sioux Falls**

Provider Number: **018042656**

Inspector: **Elijah Ehresmann**

Date of Inspection: **04/12/2019**

Time of Inspection: **2:06 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

B. ENVIRONMENTAL HEALTH

22. Does the construction of walls, ceilings, doors, window and skylights appear clean and in good repair? Does outside appearance and construction appear in good repair? 67:42:11:39

<p>Corrections To Be Made:</p> <p>There is a hole in one of the walls in the dining area.</p> <p>Walls must be clean and in good repair.</p> <p>Correction: The walls have been fixed and are in good repair.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">05/12/2019</td> <td style="text-align: center;">04/29/2019</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	05/12/2019	04/29/2019
Suggested Completion Date:	Actual Completion Date:				
05/12/2019	04/29/2019				

C. FOOD SERVICE

76. Is food free from spoilage or contamination and safe for human consumption? 67:42:11:16

Corrections To Be Made:

During the inspection, a gallon jug of milk was being stored on the counter in one of the mobile infant rooms.

Potentially hazardous food must be stored at 41 degrees F or below.

Correction: Staff have been advised that the milk must be stored in the refrigerator when not being served.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

Actual
Completion
Date:

04/12/2019

04/12/2019

Status: **Corrected Immediately**

Kelli Jurgensen

Provider Signature

04/12/2019

Date

Elijah Ehresmann

Inspector Signature

04/12/2019

Date