

Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **LSS at Here4Youth**

City: **Sioux Falls**

Provider Number: **018042746**

Inspector: **Carrie Lewis**

Date of Inspection: **10/01/2020**

Time of Inspection: **3:20 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

B. ENVIRONMENTAL HEALTH

50. Is the heating and cooling system maintained and inspected annually? 67:42:11:12

<p>Corrections To Be Made:</p> <p>Documentation for the heating and cooling system inspection was not available during the inspection.</p> <p>The heating and cooling system must be maintained and inspected annually.</p> <p>Documentation for the heating and cooling system inspection completed in 2020 was submitted to CCS.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 60%;">Suggested Completion Date:</td> <td style="width: 40%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">10/15/2020</td> <td style="text-align: center;">10/05/2020</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	10/15/2020	10/05/2020
Suggested Completion Date:	Actual Completion Date:				
10/15/2020	10/05/2020				

RiAnna Kalovsky

10/01/2020

Provider Signature

Date

Carrie Lewis

10/01/2020

Inspector Signature

Date