

Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Kinder Academy**

City: **Sioux Falls**

Provider Number: **018042917**

Inspector: **Charles Anderson**

Date of Inspection: **06/08/2018**

Time of Inspection: **3:37 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

1. Are written emergency evacuation plans posted? 67:42:10:18

<p>Corrections To Be Made:</p> <p>Available, but not posted yet.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table border="0"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">06/11/2018</td> <td style="text-align: center;">07/30/2018</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	06/11/2018	07/30/2018
Suggested Completion Date:	Actual Completion Date:				
06/11/2018	07/30/2018				

12. Are exits and exit corridors maintained in a safe manner? 61:15:05:05 NOTE: Exits can't pass through storeroom, bathroom, kitchen; corridor & aisle widths of 36 inches; exits cannot be obstructed.

<p>Corrections To Be Made:</p> <p>Deadbolt to be removed from front door and to be replaced with single-action hardware.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table border="0"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">07/08/2018</td> <td style="text-align: center;">07/30/2018</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	07/08/2018	07/30/2018
Suggested Completion Date:	Actual Completion Date:				
07/08/2018	07/30/2018				

B. ENVIRONMENTAL HEALTH

65. Is there a fenced outdoor play area? Does the fenced area appear to allow for 50 square feet per child during each scheduled recess time? 67:42:11:02

Corrections To Be Made:	Agency Action:	
	Compliance Plan	
	Suggested Completion Date:	Actual Completion Date:
	07/08/2018	07/30/2018
	Status: Corrected	

Jennifer Schuette

Provider Signature

06/08/2018

Date

Charles Anderson

Inspector Signature

06/08/2018

Date