

Facility Safety Inspection

Fire & Life Safety / Environmental Health

Licensed Day Care Programs

Compliance Plan

Provider's Name: **The SandLot**

City: **Dell Rapids**

Provider Number: **018042971**

Inspector: **Dwight Johnson**

Date of Inspection: **07/21/2020**

Time of Inspection: **1:30 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

18. Are portable fire extinguishers charged and operable? 61:15:05:10 NOTE: Minimum 2A rated on each level. No more than 75 feet travel distance to an extinguisher. One near food preparation.

Corrections To Be Made:

Fire extinguishers are of the correct type and are charged/operable, just not inspected. All extinguishers must have an annual inspection.

***Fire extinguisher inspected July 2020.**

Agency Action:

Compliance Plan

Suggested
Completion
Date:

08/21/2020

Actual
Completion
Date:

07/24/2020

Status: **Corrected**

Elly Miles

Provider Signature

07/21/2020

Date

Dwight Johnson

Inspector Signature

07/21/2020

Date