

Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Little Scholars**

City: **North Sioux City**

Provider Number: **018042975**

Inspector: **Michael Czmowski**

Date of Inspection: **10/21/2020**

Time of Inspection: **9:06 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

7. Are exit signs provided over each exit, and where necessary to identify a change in the direction of egress travel? 61:15:06:05 NOTE: Exit signs must be interior or exterior illuminated or self-luminous.

<p>Corrections To Be Made:</p> <p>The exit signs in lower level are not illuminated when tested. The batteries need to be replaced to ensure all exit signs are illuminated.</p> <p>***The batteries have been replaced in the exit signs.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">11/23/2020</td> <td style="text-align: center;">11/09/2020</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	11/23/2020	11/09/2020
Suggested Completion Date:	Actual Completion Date:				
11/23/2020	11/09/2020				

Cindy Wheatley

10/21/2020

Provider Signature

Date

Michael Czmowski

10/21/2020

Inspector Signature

Date