

Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Bright Beginnings Children's Center**

City: **Beresford**

Provider Number: **019521604**

Inspector: **Kenneth Anderson**

Date of Inspection: **08/20/2018**

Time of Inspection: **10:15 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

9. In storage rooms, are combustible materials maintained at least 2 feet below the ceiling or 18 Inches below sprinkler head deflectors? 67:42:10:18

<p>Corrections To Be Made:</p> <p>There are combustable items stored less than 2 feet from the ceiling in the storage room in the lower level of the day care.</p> <p>***Combustible items need to be stored at least two feet from the ceiling. The storage items have been moved so they are at least two feet below the ceiling.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">08/23/2018</td> <td style="text-align: center;">09/05/2018</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	08/23/2018	09/05/2018
Suggested Completion Date:	Actual Completion Date:				
08/23/2018	09/05/2018				

C. FOOD SERVICE

72. Are food containers properly stored, such as a minimum of six inches above the floor in a manner that protects from contamination and permits easy cleaning of the area, not stored under exposed or unprotected sewer or water lines, except for automatic fire system sprinkler heads, and are not in toilet rooms or vestibules? 67:42:11:18

Corrections To Be Made:

Canned food items are stored on the floor of the storage room on the main level.

*****Food items need to be stored at least six inches above the floor. A shelf has been constructed in the closet where food is stored so the items are at least 6" off the ground.**

Agency Action:

Compliance Plan

Suggested
Completion
Date:

08/23/2018

Actual
Completion
Date:

09/05/2018

Status: **Corrected**

Kari Peterson

Provider Signature

08/20/2018

Date

Kenneth Anderson

Inspector Signature

08/20/2018

Date