

Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Bright Beginnings II**

City: **Beresford**

Provider Number: **019522722**

Inspector: **Kenneth
Anderson**

Date of Inspection: **08/20/2018**

Time of Inspection: **10:49 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

9. In storage rooms, are combustible materials maintained at least 2 feet below the ceiling or 18 Inches below sprinkler head deflectors? 67:42:10:18

<p>Corrections To Be Made:</p> <p>There are combustable items stored less than 2 feet from the ceiling in the storage closet in the lower level.</p> <p>***Combustible items need to be stored at least two feet from the ceiling. The storage items have been moved so they are at least two feet below the ceiling.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">08/23/2018</td> <td style="text-align: center;">09/05/2018</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	08/23/2018	09/05/2018
Suggested Completion Date:	Actual Completion Date:				
08/23/2018	09/05/2018				

Kari Peterson

Provider Signature

08/20/2018

Date

Kenneth Anderson

Inspector Signature

08/20/2018

Date