

Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Bright Beginnings II**

City: **Beresford**

Provider Number: **019522722**

Inspector: **Kelly Gnat**

Date of Inspection: **10/26/2020**

Time of Inspection: **11:53 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

B. ENVIRONMENTAL HEALTH

43. Is the heating and cooling system maintained and inspected annually? 67:42:11:12

<p>Corrections To Be Made:</p> <p>There is not documentation for the current heating and cooling system inspection. The heating and cooling system needs to be inspected annually.</p> <p>***The documentation was received for the annual heating and cooling system inspection.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">11/07/2020</td> <td style="text-align: center;">11/03/2020</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	11/07/2020	11/03/2020
Suggested Completion Date:	Actual Completion Date:				
11/07/2020	11/03/2020				

Kari Petersen

10/26/2020

Provider Signature

Date

Kelly Gnat

10/26/2020

Inspector Signature

Date