

Facility Safety Inspection Fire & Life Safety / Environmental Health Before & After School Center - School Location Compliance Plan

Provider's Name: **The Academy of Boys and Girls Club** City: **Yankton**

Provider Number: **019525289**

Inspector: **Stacy Wildermuth** Date of Inspection: **06/11/2020**

Time of Inspection: **2:41 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

C. FOOD SERVICE

29. Does food preparation area have a sink, with running water? 67:42:11:33 NOTE: A bathroom sink cannot be used for this purpose.

<p>Corrections To Be Made:</p> <p>During the inspection, staff washed their hands in the childrens rest rooms sink prior to food preparation.</p> <p>A sink used for food preparation must be available for staff.</p> <p>Correction: A handsink used by staff to wash their hands before food preparation was installed.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">06/19/2020</td> <td style="text-align: center;">06/19/2020</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	06/19/2020	06/19/2020
Suggested Completion Date:	Actual Completion Date:				
06/19/2020	06/19/2020				

Rachel

Provider Signature

06/11/2020

Date

Stacy Wildermuth

Inspector Signature

06/11/2020

Date